



OFFICE OF ZONING AND BUILDING INSPECTION

PO Box 426 ♦ 111 Elm Street ♦ Penn Yan, NY 14527
315-536-6397 ♦ villageofpennyan.com

PHYSICAL ACCESS REQUIREMENTS FOR ELECTRIC EQUIPMENT and METERS

Clear Accessibility

Adequate clearance around electric equipment and meters to facilitate safe maintenance, inspection, meter reading and emergency access shall be maintained.

2020 Fire Code of New York State

604.3 Working space and clearance

A working space of not less than 30" in width, 36 inches in depth and 78 inches in height shall be provided in front of electrical service equipment. Where the electrical service equipment is wider than 30 inches, the working space shall be not less than the width of the equipment. Storage of materials shall not be within the designated working space.

