

Village of Penn Yan

Office of Zoning and Building Inspection

Food Truck and Trailer Inspection Checklist

Pursuant to 2020 FCNYS Section 319 Mobile Food Preparation Vehicles

Business _____

Location _____

Contact _____ Phone _____

_____ Quantity of propane (200 lbs. maximum), secured.

_____ Protection of tanks, system and piping.

_____ LP gas alarm in the vehicle. If NG, a methane alarm is required.

_____ Grease Laden vapors require a kitchen exhaust hood in accordance with FCNYS 607.

_____ Portable extinguishers.

_____ K-extinguisher 20 lbs. minimum.

_____ ABC extinguisher 15 lbs. minimum.

_____ All extension cords shall be covered, protected and shall not cause a trip hazard.

_____ Maintenance and inspection done annually – tagged or stickered.

_____ Health Department valid certificate.

_____ Date of certificate _____ .

CEO Comments _____

CEO Approved _____ Date _____

CEO Denied _____ Date _____

All food trucks applying for an Operating Permit are required to be inspected.